

**ANALYZING CARBON EMISSIONS AND RENEWABLE ENERGY INTEGRATION
STRATEGIES FOR ENVIRONMENTALLY SUSTAINABLE DATA CENTRE
INFRASTRUCTURE DEVELOPMENT****Prindal Rawal**

DePaul University, USA

ABSTRACT

The global expansion of digital infrastructure, driven by cloud computing, artificial intelligence, streaming services, and increasingly data-intensive economic activities, has intensified concerns regarding the environmental footprint of data centres. Their substantial electricity requirements can increase carbon emissions when operations depend heavily on fossil-fuel-based power systems, creating tension between digital transformation and climate objectives. This study analyzes carbon emissions associated with data centre infrastructure and evaluates renewable energy integration strategies for improving environmental sustainability. The analysis considers operational electricity consumption, grid carbon intensity, cooling demand, facility efficiency, and indirect emissions associated with supporting energy infrastructure. It further examines renewable electricity procurement, on-site solar and wind generation, power purchase agreements, battery energy storage, demand response, workload scheduling, and grid-interactive operations as potential decarbonization pathways. Particular attention is given to intermittency, energy matching, reliability requirements, and differences between annual renewable procurement and real-time carbon-free electricity consumption. The study provides an integrated framework for aligning expanding computational capacity with emissions reduction, energy resilience, and long-term environmentally sustainable data centre infrastructure development.

Keywords:

Data Centres; Carbon Emissions; Renewable Energy; Digital Infrastructure; Energy Sustainability; Decarbonization

1. INTRODUCTION**1.1 Expansion of Data Centres and Rising Electricity Demand**

Rapid expansion of data centre infrastructure reflects growing dependence on cloud computing, artificial intelligence, high-performance computing, streaming platforms, digital services, and increasingly data-intensive economic activities [1]. These applications require expanding computational capacity through additional servers, storage systems, networking equipment, and specialized processors capable of supporting intensive and continuously operating workloads [5]. Artificial intelligence further increases infrastructure requirements because large-scale model training and inference can involve substantial computational intensity and high-density accelerator deployment [9]. Greater computing capacity consequently translates into higher electricity requirements for both IT equipment and supporting facility systems [2]. Rising server density also increases heat generation, requiring corresponding cooling, power-conversion, and electrical-distribution capacity [6]. At larger scales, these requirements extend beyond individual facilities because concentrated data centre development can require additional generation, transmission capacity, substations, and grid connections [8]. Data centre growth should therefore be understood as both digital infrastructure expansion and physical energy-system expansion, with increasing computational demand creating significant implications for electricity consumption, power infrastructure, and environmental sustainability [3].

1.2 Carbon Implications of Data Centre Infrastructure Development

The carbon footprint of data centres extends across operational electricity consumption, cooling, backup power, construction, equipment manufacturing, and infrastructure development [3]. Operational emissions are strongly influenced by electricity consumption and the generation mix supplying the facility; identical electricity requirements can produce substantially different emissions depending on the carbon intensity of grid electricity [8]. Cooling systems contribute indirectly by increasing facility electricity demand, while diesel or other fossil-fuel backup generators can generate direct emissions during operation and testing [6]. Beyond operations, constructing buildings and electrical infrastructure and manufacturing servers, cooling equipment, batteries, and other hardware create embodied emissions before equipment becomes operational [4]. Continued capacity

expansion can therefore increase lifecycle emissions even when individual facilities become more energy efficient [5]. This creates tension between accelerating digitalization and wider decarbonization objectives [7]. If rapidly increasing electricity demand stimulates additional fossil-based generation or delays power-sector decarbonization, digital infrastructure growth may amplify emissions pressures, making electricity sourcing and lifecycle carbon management central to sustainable development [9].

1.3 Study Aim, Scope, and Analytical Direction

This study analyzes the principal carbon-emission pathways associated with expanding data centres and evaluates renewable-energy integration strategies capable of supporting environmentally sustainable infrastructure development [1]. The analysis distinguishes operational emissions arising primarily from electricity consumption and backup generation from embodied emissions associated with construction, equipment production, replacement, and supporting infrastructure [4]. Grid carbon intensity is examined as a critical determinant of operational emissions because the environmental consequences of electricity demand vary according to generation technology, location, and time [6]. Renewable procurement is consequently assessed alongside physical renewable generation and the temporal alignment between clean-electricity availability and computing demand [8]. Energy storage and demand flexibility are considered as mechanisms for improving renewable utilization and reducing dependence on carbon-intensive electricity during constrained periods [2]. The study additionally evaluates carbon-aware computing, through which flexible workloads can respond to changing electricity-system carbon conditions [7]. Together, these dimensions establish an integrated perspective connecting computational growth, energy consumption, lifecycle emissions, renewable supply, operational flexibility, and grid decarbonization [9].

2. CARBON FOOTPRINT OF EXPANDING DATA CENTRE INFRASTRUCTURE

2.1 Operational Electricity Consumption and Carbon Emissions

Operational carbon emissions from data centres are closely linked to the electricity required to maintain continuous computing and supporting infrastructure [6]. Servers constitute a major load through processors, memory, accelerators, and other components, while storage and networking equipment add further electricity requirements as data volumes and traffic increase [11]. Cooling systems consume additional energy through chillers, pumps, fans, cooling towers, and air-handling equipment needed to remove server-generated heat [8]. Power-conversion infrastructure, including uninterruptible power supplies, transformers, and distribution equipment, introduces further consumption and conversion losses, while lighting, security, monitoring, and auxiliary systems contribute smaller but persistent loads [12]. Electricity consumption becomes operational carbon emissions according to the carbon intensity of the electricity supplying the facility [14]. Consequently, identical data centres can produce different operational emissions when connected to grids with different generation portfolios [13]. Carbon intensity can also vary temporally as renewable, nuclear, gas, coal, and other generation sources change their contribution to electricity supply [15]. Operational decarbonization therefore requires attention to both the quantity of electricity consumed and its generation source [9].

2.2 Direct, Indirect, and Embodied Emission Sources

Data centre carbon footprints extend beyond purchased electricity and can be separated into direct, indirect, and embodied emission sources [8]. Direct emissions arise principally from fuels combusted within the facility boundary, including diesel or gas used by emergency generators during testing, outages, or other operational requirements [12]. Indirect electricity emissions result from generation of the purchased power required for computing, cooling, power distribution, and supporting systems [14]. Embodied emissions arise across infrastructure and equipment lifecycles, beginning with extraction and processing of raw materials and continuing through manufacturing, transportation, construction, replacement, and eventual disposal [11]. Concrete and steel used in buildings and electrical infrastructure can therefore contribute substantial upfront carbon, while servers, networking equipment, batteries, cooling systems, and power electronics create additional manufacturing and supply-chain impacts [13]. Frequent replacement of computing hardware can further increase lifecycle emissions even where newer equipment provides greater operational efficiency [10]. Infrastructure expansion also requires substations, transmission connections, backup systems, and associated materials [15]. Comprehensive carbon assessment must consequently capture both recurring operational emissions and emissions embodied within physical infrastructure and technology supply chains [6].

2.3 Carbon Accounting and Environmental Performance Indicators


Carbon accounting provides a structured basis for distinguishing emission sources and evaluating decarbonization performance [7]. Scope 1 includes direct emissions from sources controlled by the operator, such as on-site fuel combustion, while Scope 2 captures emissions associated with purchased electricity [9]. Relevant Scope 3 categories can include construction materials, purchased equipment, upstream supply chains, transportation, hardware replacement, and other lifecycle activities outside direct operational control [13]. Carbon intensity may

IJETRM

INTERNATIONAL JOURNAL OF ENGINEERING TECHNOLOGY RESEARCH & MANAGEMENT (IJETRM)

<https://ijetrm.com/>

be expressed relative to electricity consumption or, where suitable workload information exists, computational output, allowing environmental performance to be related to operational activity [15]. PUE remains useful for assessing facility energy overhead by comparing total facility energy with IT-equipment energy [11]. However, lower PUE does not necessarily indicate lower carbon emissions because it neither identifies the carbon intensity of electricity nor captures embodied emissions and absolute growth in consumption [14]. Lifecycle carbon assessment therefore complements operational indicators by incorporating infrastructure construction, equipment production, use, replacement, and end-of-life impacts [10]. Robust sustainability assessment should consequently combine efficiency, absolute energy, carbon-intensity, and lifecycle indicators [12].

Figure 1. Carbon Emission Pathways Across the Data Centre Infrastructure Lifecycle**Figure 1. Carbon Emission Pathways Across the Data Centre Infrastructure Lifecycle**

3. RENEWABLE ENERGY INTEGRATION STRATEGIES

3.1 On-Site Renewable Energy Generation

On-site renewable generation provides data centres with a direct mechanism for reducing dependence on grid electricity and lowering operational carbon exposure [13]. Solar photovoltaic systems are particularly applicable because they can be installed on rooftops, parking structures, adjacent land, or dedicated facility sites and can supply electricity without operational combustion emissions [14]. However, generation is restricted to daylight periods and varies with weather, season, latitude, and available installation area [17]. Large-scale data centres operate continuously and can require power capacities substantially exceeding what constrained facility footprints can accommodate through solar generation alone [15]. Wind generation can provide complementary renewable electricity where wind resources, land availability, planning conditions, and turbine siting are suitable [18]. Its variable generation profile nevertheless creates similar challenges for continuously operating computational loads [20]. Hybrid systems combining solar, wind, storage, and grid electricity can improve renewable availability by exploiting complementary generation profiles [16]. Yet land requirements, intermittency, resource variability, capital expenditure, and facility scale constrain exclusive reliance on on-site renewables [19]. Consequently, on-site generation is most effective as one component of a broader electricity-procurement and energy-management strategy rather than as a universally sufficient source for large data centres [13].

3.2 Off-Site Renewable Procurement and Power Purchase Agreements

Off-site procurement enables data centres to support renewable generation at scales that may be impossible within facility boundaries [14]. Corporate power purchase agreements (PPAs) can establish long-term contractual arrangements with renewable-energy projects, providing revenue certainty for developers while allowing operators to associate electricity consumption with renewable generation [17]. Physical PPAs can involve electricity delivery through the relevant grid, whereas virtual or financial PPAs primarily settle electricity-market price differences without requiring the contracted renewable electricity to flow physically to the data centre [18]. Green tariffs and utility renewable programs provide alternative mechanisms through which customers purchase electricity associated with designated renewable resources [15]. Renewable-energy certificates can document renewable attributes and support accounting claims, while direct procurement may establish closer relationships between facilities and specific generation assets [19]. These mechanisms, however, should not automatically be interpreted as equivalent forms of physical decarbonization [20]. Electricity delivered to a grid-connected data centre generally reflects the generation operating within the interconnected power system at that time [16]. Consequently, contractual renewable claims can differ from actual electricity flows and marginal grid emissions. Stronger decarbonization therefore depends on procurement additionality, geographic relevance, temporal alignment, and whether renewable investment meaningfully displaces or avoids carbon-intensive generation [13].

3.3 Temporal and Spatial Renewable Energy Matching

Annual renewable matching compares total renewable electricity procured or generated over a year with annual data centre electricity consumption [15]. Although this approach can demonstrate equivalent renewable procurement on an aggregate basis, it can conceal substantial temporal differences between renewable generation and continuous computing demand [17]. A facility may procure sufficient solar electricity to match annual consumption while continuing to depend on carbon-intensive grid generation during nights, periods of low renewable output, or times of peak electricity demand [18]. Hourly or 24/7 carbon-free energy matching addresses this limitation by seeking closer alignment between facility consumption and carbon-free electricity availability during each operating period [20]. Such matching provides a more granular representation of the emissions consequences associated with continuous digital workloads [16]. Spatial alignment is equally important because renewable generation located in a different electricity system may have limited influence on the generation mix physically serving the data centre [13]. Locational grid constraints, transmission congestion, regional generation portfolios, and marginal electricity sources can therefore affect realized carbon reductions [19]. Combining temporal and spatial matching encourages renewable procurement where and when data centre demand occurs [14]. However, achieving high levels of continuous carbon-free supply can require diversified renewable portfolios, energy storage, demand flexibility, grid coordination, and sophisticated carbon accounting [18]. Renewable integration should therefore progress beyond annual attribute matching toward location-sensitive, time-resolved strategies that more closely connect procurement decisions with actual electricity-system decarbonization [20].

Table 1. Comparative Assessment of Renewable Energy Integration Strategies for Data Centres

Strategy	Integration Mode	Carbon Potential	Reduction	Reliability Contribution	Major Constraint
On-site solar	Direct generation	Moderate–high		Limited	Space/intermittency
On-site wind	Direct generation	High where suitable		Variable	Location
PPA	Off-site procurement	High		Indirect	Contract/grid dependence
Green tariff	Utility-based	Variable		Grid dependent	Availability
24/7 matching	Temporal matching	High		Stronger alignment	Complexity/cost
Hybrid renewables	Multiple sources	High		Improved	Capital requirements

4. ENERGY STORAGE, GRID INTERACTION, AND RENEWABLE RELIABILITY

4.1 Renewable Intermittency and Continuous Data Centre Loads

The continuous operating requirements of large-scale data centres create a fundamental challenge for integrating variable renewable electricity [18]. Computational workloads, storage, networking, cooling, and auxiliary systems can operate continuously, with operators requiring exceptionally high availability and resilience against electricity-supply interruptions [20]. Solar generation follows daylight and weather conditions, while wind output varies according to meteorological conditions and can fluctuate independently of facility demand [23]. Consequently, renewable generation may exceed demand during some periods yet remain insufficient during others [21]. Peak computational or cooling demand may also occur when renewable availability is limited, increasing dependence on grid electricity or backup resources [24]. Reliability requirements further encourage redundant power pathways, uninterruptible power supplies, backup generation, and reserve capacity capable of maintaining operations during disturbances [19]. Even facilities procuring substantial renewable electricity therefore remain dependent on grid infrastructure unless adequate storage or dispatchable resources are available [22]. Sustainable integration consequently requires balancing renewable penetration with continuous availability, peak-load requirements, system redundancy, and the operational reliability expected from critical digital infrastructure [25].

4.2 Energy Storage for Renewable Integration

Energy storage can reduce temporal mismatches between renewable generation and data centre electricity demand by shifting energy from periods of surplus production to periods of higher demand or lower renewable availability [21]. Battery energy storage systems can support peak shaving, short-duration renewable shifting, backup power, frequency regulation, and other grid services while responding rapidly to changing electricity conditions [23]. Their integration with existing uninterruptible power infrastructure may also create opportunities to use installed battery capacity more dynamically rather than reserving it exclusively for emergencies [20]. Thermal energy storage provides another pathway by storing cooling capacity and shifting electricity-intensive cooling processes away from periods of peak grid demand or elevated carbon intensity [24]. Emerging long-duration storage technologies could potentially address longer renewable deficits that conventional batteries cannot economically cover [22]. However, storage is not environmentally impact-free. Battery manufacturing involves material extraction, processing, transportation, and eventual replacement or recycling, creating embodied lifecycle impacts [25]. Capital costs, degradation, efficiency losses, storage duration, safety requirements, and physical space also influence feasibility [19]. Storage deployment should therefore be evaluated through lifecycle and system-level assessment rather than solely according to operational carbon reductions [18].

4.3 Grid-Interactive Data Centre Operations

Grid-interactive operation can enable data centres to move from relatively inflexible electricity consumers toward active participants in power-system balancing [20]. Demand-response programs can temporarily modify non-critical electricity consumption when grids experience high demand, constrained generation, or other operational pressures [23]. Microgrids can coordinate on-site renewable generation, batteries, backup resources, and facility loads, providing greater control over electricity sourcing and resilience [21]. Smart energy-management systems can additionally combine workload forecasts, renewable availability, electricity prices, storage status, and grid conditions to optimize facility operation [24]. Flexible loads, including selected cooling processes and delay-tolerant computational tasks, may be shifted without compromising essential digital services [22]. Data centres can potentially provide frequency response, reserve capacity, peak reduction, or other grid-balancing services

through coordinated storage and controllable demand [25]. Such participation nevertheless requires reliable controls, appropriate market structures, cybersecurity safeguards, and clear operational boundaries protecting service availability [19]. When these conditions are satisfied, grid-interactive facilities can improve renewable utilization while contributing flexibility to increasingly variable electricity systems [18].

5. CARBON-AWARE COMPUTING AND OPERATIONAL DECARBONIZATION

5.1 Energy-Efficient Computing and Infrastructure Optimization


Reducing the electricity required to deliver computational services provides a direct mechanism for limiting the operational emissions associated with data centre growth [23]. Higher server utilization can reduce the number of underused machines consuming electricity, while virtualization and workload consolidation allow computing resources to be allocated more efficiently across physical infrastructure [26]. Efficient processors and accelerators can further reduce energy consumption per computational task when appropriately matched to workload requirements [28]. Dynamic power management can place processors, storage, and other equipment into lower-power states when utilization decreases [24]. Infrastructure optimization should simultaneously address cooling because inefficient thermal management increases facility electricity consumption beyond the energy required by IT equipment [27]. Improved airflow management, temperature control, efficient cooling equipment, and advanced liquid cooling can reduce this overhead [30]. These measures can contribute to lower PUE by decreasing non-IT electricity requirements [25]. However, efficiency improvements should be evaluated alongside absolute electricity consumption because expanding computational demand can offset facility-level efficiency gains [29]. Effective decarbonization therefore requires improvements in both computing productivity and supporting infrastructure efficiency [23].

5.2 Temporal and Geographic Workload Shifting

Flexible computational workloads can potentially be shifted toward times when renewable electricity is abundant or grid carbon intensity is comparatively low [24]. Temporal shifting may delay suitable batch processing, model training, data analytics, or other non-urgent tasks until periods characterized by greater solar or wind availability [28]. Geographic shifting extends this principle by transferring workloads between data centres located in regions with different renewable resources, electricity-system conditions, and carbon intensities [30]. Such strategies can reduce emissions without necessarily reducing the total quantity of computation performed [26]. However, workload flexibility is constrained by application requirements. Latency-sensitive services may require immediate processing close to users, limiting both temporal and geographic relocation [27]. Data sovereignty and privacy requirements can restrict movement of information across national or regional boundaries [25]. Reliability, network capacity, electricity availability, computational capacity, and service-level agreements create additional operational constraints [29]. Geographic carbon comparisons must also account for differences in grid conditions and renewable availability rather than assuming that a nominally renewable-rich location is consistently lower carbon [23]. Workload shifting is therefore most applicable to computational activities with sufficient temporal and geographic flexibility [28].

5.3 Carbon-Aware Scheduling and Intelligent Energy Management

Carbon-aware scheduling extends workload flexibility by integrating information about electricity-system emissions directly into computational decision-making [26]. Forecasting systems can estimate future workload demand, renewable generation, electricity prices, cooling requirements, and grid carbon intensity, allowing suitable tasks to be scheduled during environmentally preferable operating periods [28]. Real-time carbon-intensity signals can further support dynamic decisions when electricity-generation conditions differ from forecasts [30]. Automated scheduling platforms can prioritize urgent workloads while delaying, accelerating, or relocating flexible computation according to predefined carbon and operational constraints [24]. AI-enabled energy-management systems can coordinate servers, cooling equipment, batteries, on-site renewable generation, and grid interaction as interconnected resources rather than optimizing each independently [27]. This creates opportunities to align computational demand with renewable availability while simultaneously controlling facility energy overhead [29]. Effective implementation nevertheless requires accurate carbon data, reliable forecasting, transparent optimization objectives, and safeguards preventing carbon optimization from compromising latency, security, or availability [25]. Coordinated computing-energy management can therefore transform decarbonization from static renewable procurement into an adaptive operational process responding continuously to workload requirements and electricity-system conditions [23].

Figure 2. Integrated Renewable Energy and Carbon-Aware Data Centre Operating Model**Figure 2. Integrated Renewable Energy and Carbon-Aware Data Centre Operating Model****6. CHALLENGES AND TRADE-OFFS IN DATA CENTRE DECARBONIZATION****6.1 Technical and Infrastructure Constraints**

Data centre decarbonization is constrained by electricity-system and infrastructure limitations that can restrict the effective integration of renewable generation [27]. Grid connection capacity represents a significant challenge where rapidly expanding facilities create large, concentrated electricity loads that exceed available network capacity [29]. Renewable intermittency further complicates continuous operation because solar and wind

generation cannot independently guarantee electricity availability at every hour [31]. Transmission constraints can prevent renewable electricity generated in resource-rich regions from reaching major data centre clusters when required [30]. Energy storage can reduce these temporal imbalances, but required capacity increases with the duration and magnitude of renewable shortfalls [32]. Reliability standards also require redundancy and backup resources, potentially maintaining dependence on conventional generation [28]. Geographic differences in renewable potential, climate, and electricity infrastructure further affect feasible decarbonization pathways [33]. These challenges are intensified by AI-oriented infrastructure, where accelerator-dense computing environments increase rack power densities and aggregate facility electricity requirements, placing additional pressure on grid connections, cooling systems, and supporting infrastructure [27].

6.2 Environmental and Lifecycle Trade-offs

Operational electricity decarbonization represents only one component of the environmental consequences associated with expanding data centre infrastructure [29]. Renewable-energy technologies themselves contain embodied emissions arising from raw-material extraction, component manufacturing, transportation, construction, installation, maintenance, and end-of-life processing [31]. Battery storage similarly introduces lifecycle impacts associated with mineral extraction, cell production, replacement, and recycling [32]. Data centres additionally require carbon-intensive construction materials, electrical equipment, cooling infrastructure, and continuously evolving computing hardware [30]. Frequent server replacement can increase embodied emissions even where newer equipment improves computational energy efficiency [28]. Expanding supply chains for semiconductors, batteries, cooling systems, and renewable technologies therefore influence the overall carbon consequences of digital infrastructure development [33]. Assessments based exclusively on operational electricity may consequently underestimate emissions or shift environmental burdens to upstream stages [27]. Lifecycle carbon assessment should integrate construction, renewable infrastructure, equipment manufacturing, operational energy, maintenance, replacement, and end-of-life impacts to determine whether decarbonization strategies produce genuine reductions across the complete infrastructure lifecycle [29].

6.3 Economic and Governance Challenges

Decarbonization strategies are also shaped by investment requirements, electricity-market conditions, renewable availability, contractual arrangements, and carbon-accounting practices [28]. On-site generation, storage, advanced cooling, microgrids, and grid upgrades can require substantial capital expenditure, while electricity prices influence the economic attractiveness of different operational strategies [30]. Renewable availability varies geographically, potentially limiting procurement choices or increasing dependence on distant projects and contractual instruments [32]. Power purchase agreements, green tariffs, and renewable certificates can support renewable development, but their environmental value depends on additionality, location, timing, and interaction with the physical electricity system [31]. Carbon-accounting methodologies therefore influence whether procurement arrangements represent measurable emissions reductions or primarily contractual renewable claims [33]. Inconsistent reporting boundaries can further complicate comparisons among facilities and operators [27]. Transparent disclosure should distinguish Scope 1, Scope 2, and relevant Scope 3 emissions while reporting electricity consumption, grid carbon intensity, renewable sourcing, and temporal matching [29]. Effective governance must consequently connect investment and procurement decisions with verifiable lifecycle carbon outcomes [28].

Table 2. Key Barriers, Trade-offs, and Mitigation Strategies for Data Centre Decarbonization

Challenge	Carbon Implication	Sustainability Trade-off	Mitigation Strategy	Performance Indicator
Renewable intermittency	Fossil backup	Reliability	Storage/hybrid supply	Carbon intensity
Grid constraints	Higher grid emissions	Location dependence	Grid-responsive operation	Hourly emissions
Storage requirements	Embodied carbon	Reliability vs lifecycle impact	Lifecycle optimization	Storage carbon footprint
High computing demand	Rising electricity use	Digital growth vs emissions	Efficiency/workload management	Energy per workload
Carbon accounting	Misleading claims	Reporting complexity	Transparent accounting	Scope 1–3 emissions

7. FRAMEWORK FOR ENVIRONMENTALLY SUSTAINABLE DATA CENTRE DEVELOPMENT**7.1 Architecture of the Integrated Decarbonization Framework**

An integrated decarbonization framework should connect infrastructure planning with electricity demand, renewable sourcing, energy storage, workload management, grid interaction, carbon accounting, and lifecycle environmental performance [32]. Infrastructure planning establishes the foundation because facility location, computational capacity, server density, cooling architecture, grid connectivity, and expansion expectations determine long-term energy and carbon characteristics [34]. Electricity demand should subsequently be minimized through efficient computing and supporting systems before additional supply-side interventions are considered [37]. Renewable electricity can reduce operational carbon intensity, while storage improves temporal alignment between variable generation and continuous facility loads [36]. Grid interaction provides additional flexibility through demand response, microgrids, and coordinated energy management [40]. Workload management can complement these measures by shifting suitable computational activity toward lower-carbon periods or locations [38]. Carbon accounting should then quantify direct emissions, purchased-electricity emissions, and relevant supply-chain impacts rather than concentrating exclusively on operational electricity [35]. Lifecycle considerations extend this assessment across construction, equipment manufacturing, replacement, expansion, and decommissioning [39]. The framework therefore operates as an interconnected system in which planning, efficiency, clean electricity, flexibility, and carbon measurement continuously inform infrastructure and operational decisions [33].

7.2 Carbon and Renewable-Energy Performance Indicators

Effective implementation requires indicators capable of distinguishing energy efficiency, renewable integration, operational emissions, and lifecycle carbon performance [32]. PUE measures the relationship between total facility energy consumption and IT-equipment energy, providing insight into infrastructure overhead but not directly measuring carbon emissions [34]. Renewable-energy share indicates the proportion of electricity associated with renewable sources, while hourly carbon intensity reveals the emissions characteristics of electricity consumed at particular times [36]. Renewable matching should additionally indicate whether clean electricity procurement corresponds temporally and geographically with facility demand [38]. Emissions per unit of computing activity can connect carbon performance with useful computational output and help distinguish genuine efficiency improvements from reductions caused merely by lower workloads [40]. Scope 1, Scope 2, and relevant Scope 3 inventories provide complementary organizational accounting boundaries [35]. Storage utilization indicators can measure charging, discharge, renewable shifting, and grid-support functions [37]. Lifecycle carbon indicators should capture emissions from construction materials, servers, cooling equipment, batteries, renewable infrastructure, replacements, and end-of-life activities [39]. Together, these indicators provide a multidimensional basis for monitoring decarbonization progress [33].

7.3 Multi-Strategy Decarbonization and Decision Optimization

No single intervention can address the interconnected carbon consequences of large-scale data centre expansion [34]. Energy-efficiency improvements reduce the electricity required for computing and supporting infrastructure, but continuing workload growth can offset these gains through increased absolute consumption [38]. Renewable electricity reduces operational carbon intensity, yet intermittency and imperfect temporal matching can preserve dependence on carbon-intensive grid generation during particular periods [36]. Storage can shift renewable electricity and provide flexibility, although batteries introduce cost, efficiency losses, material requirements, and embodied emissions [39]. Workload flexibility can relocate suitable computing activity toward periods of greater renewable availability, while carbon-aware scheduling can automate decisions using time-sensitive electricity-system information [40]. Cooling optimization further reduces non-IT energy requirements and can become increasingly important as AI-oriented equipment increases thermal density [32]. These measures should therefore be optimized collectively rather than implemented independently [37]. Decision models can evaluate electricity consumption, carbon intensity, renewable availability, storage state, workload requirements, cooling demand, reliability constraints, and lifecycle impacts simultaneously [35]. Multi-strategy optimization consequently provides a more resilient decarbonization pathway by balancing emissions reduction with computational performance, electricity reliability, infrastructure feasibility, and long-term environmental sustainability [33].

7.4 Implementation Across the Data Centre Lifecycle


Carbon management should begin before a data centre becomes operational and continue throughout the infrastructure lifecycle [32]. During site selection, developers should evaluate grid carbon intensity, renewable-resource availability, transmission capacity, climate conditions, and opportunities for future clean-energy integration [36]. Design decisions should incorporate efficient computing architecture, low-energy cooling, renewable generation, storage readiness, and flexible grid interfaces [34]. Construction should address embodied emissions through material selection, infrastructure efficiency, and lower-carbon procurement practices [39].

IJETRM

INTERNATIONAL JOURNAL OF ENGINEERING TECHNOLOGY RESEARCH & MANAGEMENT (IJETRM)

<https://ijetrm.com/>

Equipment procurement should similarly consider operational efficiency, manufacturing impacts, expected service life, repairability, and replacement requirements [35]. During operation, facilities can combine renewable procurement, storage, intelligent cooling, carbon-aware workload management, and continuous emissions monitoring [40]. Expansion decisions should assess whether additional computational capacity requires new grid infrastructure or increases reliance on carbon-intensive generation [38]. Technology replacement should balance efficiency gains against embodied emissions from premature hardware turnover [37]. Finally, decommissioning should prioritize equipment reuse, material recovery, recycling, and responsible disposal [33]. Lifecycle implementation therefore embeds carbon considerations into decisions from initial planning through final infrastructure retirement.

Figure 3. Integrated Framework for Low-Carbon and Renewable-Powered Data Centre Infrastructure Development**Figure 3. Integrated Framework for Low-Carbon and Renewable-Powered Data Centre Infrastructure Development****8. FUTURE DIRECTIONS AND SUSTAINABILITY IMPLICATIONS****8.1 Emerging Decarbonization Technologies**

Future data centre decarbonization will increasingly depend on technologies capable of coordinating high-density computing with cleaner and more flexible energy systems [32]. Advanced batteries and emerging long-duration

storage technologies could improve renewable integration by extending electricity shifting beyond short-duration applications [36]. Next-generation liquid and immersion cooling can improve heat removal from increasingly dense AI-oriented hardware while potentially reducing cooling-related electricity requirements [34]. AI-enabled energy optimization can integrate workload forecasts, renewable availability, storage conditions, cooling requirements, electricity prices, and grid carbon signals to support adaptive facility control [40]. Waste-heat recovery could further improve resource efficiency by supplying usable thermal energy to nearby buildings or industrial applications [37]. Low-carbon concrete, steel, construction methods, and equipment procurement can reduce embodied infrastructure emissions [39]. Microgrids can coordinate renewable generation, storage, flexible demand, and backup resources locally [35]. Increasingly granular carbon-aware computing can additionally schedule workloads according to hourly or potentially finer-resolution electricity conditions, creating stronger alignment between digital activity and low-carbon energy availability [38].

8.2 Strategic Priorities for Sustainable Digital Infrastructure

Long-term sustainability requires coordinated action extending beyond individual data centre facilities [33]. Cleaner electricity grids remain fundamental because grid decarbonization reduces emissions across both existing and expanding computational infrastructure [36]. Transparent carbon accounting should distinguish direct emissions, purchased-electricity emissions, embodied impacts, renewable procurement, and relevant supply-chain emissions [35]. Progressing from annual renewable claims toward 24/7 matching can strengthen temporal correspondence between clean generation and continuous data centre demand [40]. Lifecycle assessment should accompany operational indicators so that construction, equipment manufacturing, batteries, cooling technologies, replacement cycles, and decommissioning remain visible within environmental decisions [39]. Infrastructure flexibility should also be strengthened through storage, demand response, grid-interactive controls, and adaptable workload management [38]. Standardized environmental reporting would improve comparability and reduce ambiguity surrounding corporate decarbonization claims [32]. Achieving these priorities requires collaboration among data centre operators, electricity utilities, regulators, technology suppliers, communities, and renewable-energy developers [37]. Such coordination can align digital infrastructure investment with grid planning, renewable deployment, reliability requirements, transparent emissions measurement, and long-term decarbonization objectives [34].

9. CONCLUSION

9.1 Synthesis of Carbon and Renewable Energy Findings

Rapid data centre expansion creates carbon impacts through interconnected operational and infrastructure pathways rather than electricity consumption alone. Continuous computing requires substantial power for servers, storage, networking, cooling, power conversion, and auxiliary systems, while backup generation introduces additional direct emissions. Beyond operations, construction materials, renewable-energy infrastructure, batteries, cooling equipment, server manufacturing, transportation, replacement cycles, and wider supply chains contribute embodied carbon throughout the infrastructure lifecycle. Renewable electricity can substantially reduce operational emissions, but procurement should not automatically be equated with physical decarbonization. Annual renewable-energy certificates, tariffs, or contractual procurement may establish renewable claims without ensuring that carbon-free electricity is available at the location and time of actual consumption. Consequently, credible environmental assessment requires distinguishing contractual renewable matching from measurable reductions in grid-related emissions. Data centre decarbonization must therefore consider electricity quantity, generation source, temporal availability, geographic relevance, infrastructure development, and lifecycle emissions together when evaluating environmental performance and renewable-energy effectiveness.

9.2 Pathway Toward Environmentally Sustainable Data Centres

Environmentally sustainable data centre development requires a coordinated portfolio of interventions rather than dependence on any single technology or procurement mechanism. Energy-efficient computing, server consolidation, optimized cooling, and power-management systems can reduce underlying electricity demand, while renewable generation and procurement can lower the carbon intensity of remaining consumption. Temporal renewable matching, energy storage, grid-responsive operation, and flexible workload management can address mismatches between continuous computing demand and variable clean-energy availability. Carbon-aware scheduling can further align computational activity with periods and locations characterized by lower electricity-system emissions. These operational measures should be complemented by lifecycle management addressing construction, equipment procurement, infrastructure expansion, technology replacement, and eventual decommissioning. Transparent Scope 1–3 accounting and consistent performance indicators are equally necessary for distinguishing demonstrated emissions reductions from accounting-based claims. The integrated framework developed in this study therefore provides a pathway for coordinating infrastructure planning, energy efficiency,

renewable sourcing, storage, grid flexibility, computing operations, and lifecycle carbon management, enabling expanding computational capacity to progress alongside long-term decarbonization and environmental sustainability objectives.

REFERENCE

- 1) Plattner B. Smart Infrastructure and Sustainable AI Data Centres Carbon-Native DCIM Big Data Storage Observability and Cloud Resource Optimization. *International Journal of Computer Technology and Electronics Communication*. 2024 Aug 16;7(4):9162-71.
- 2) Zhang Y, Wang Y, Wang X. Greenware: Greening cloud-scale data centers to maximize the use of renewable energy. In *ACM/IFIP/USENIX international conference on distributed systems platforms and open distributed processing* 2011 Dec 12 (pp. 143-164). Berlin, Heidelberg: Springer Berlin Heidelberg.
- 3) Almhdi E, Miskeen G. Power and carbon footprint evaluation and optimization in transitioning data centres. *Wadi Alshatti University Journal of Pure and Applied Sciences*. 2025 Sep 21;3(2):221-9.
- 4) Oluwatobi Alebiosu. Quantifying regulatory delay risk transmission across utility-scale renewable energy projects in hydrocarbon-dominant economies. *Int J Hydropower Civ Eng* 2023;4(1):35-47. DOI: [10.22271/27078302.2023.v4.i1a.89](https://doi.org/10.22271/27078302.2023.v4.i1a.89)
- 5) Aziz F. Analyze the Impact of Energy Consumption and Carbon Footprint on Large Scale AI Models and Data Centers. *Indus Journal of Critical Inquiry (IJCI)*. 2025;3(1):01-8.
- 6) Veselova V. Data Center Sustainability Reporting: Advancement of Assessment Methodology for Energy Consumption by Virtualized Resources in Data Centers.
- 7) Chukwunweike J. Coordinating PLC-based load shedding and variable-speed drives to prevent transformer overloading during industrial production peaks. *Int J Electr Data Commun*. 2025;6(2 Pt B):118-135. doi:10.22271/27083969.2025.v6.i2b.109.
- 8) Kong F, Liu X. A survey on green-energy-aware power management for datacenters. *ACM Computing Surveys (CSUR)*. 2014 Nov 12;47(2):1-38.
- 9) Koronen C, Åhman M, Nilsson LJ. Data centres in future European energy systems—energy efficiency, integration and policy. *Energy efficiency*. 2020 Jan;13(1):129-44.
- 10) Asante, A., Daramola, G., Davis, R. W., & Kumar, S. (2025). Environmentally Friendly Chelation for Enhanced Algal Biomass Deashing. *Phycology*, 5(3), 32. <https://doi.org/10.3390/phyecology5030032>
- 11) Reddy VJ, Hariram NP, Ghazali MF, Kumarasamy S. Pathway to sustainability: An overview of renewable energy integration in building systems. *Sustainability*. 2024 Jan 11;16(2):638.
- 12) Sikder AS, Ahmed S, Islam J. Leveraging information technology for green IT and sustainable development: an analysis of environmental sustainability, energy efficiency, and carbon footprint reduction initiatives.: IT for green IT and sustainable development. *International Journal of Imminent Science & Technology*.. 2023;1(1):48-63.
- 13) Goh KC, Kurniawan TA, Kong JW, Casila EB, Masrom MA, Mohamed S, Sarpin N, Chong WS, Gui HC, Toh TC, Onn CW. Accelerating Decarbonization in Data Center Infrastructure in Smart Cities With Digitalization: Insights From Shenzhen (China) and Cyberjaya (Malaysia) for Promoting Net-Zero Emissions. *Journal of the Knowledge Economy*. 2026 Sep 25:1-54.
- 14) Eseoghene OM. Applying blockchain-based fraud prevention mechanisms for securing digital banking transactions and strengthening customer trust in financial institutions worldwide. *International Journal of Research Publication and Reviews*. 2025;6(9):351-67.
- 15) Afzal Y, Nawaz N, Khan AA, Yousaf MJ, Khan MZ, Arif E, Salahuddin M, Mohamed MA, Ullah S. Sustainable Control of Carbon Emissions and Energy Consumption Through a Green Data Center Approach. *The Scientific World Journal*. 2026;2026(1):1158756.
- 16) Aldossary M, Alharbi HA. An eco-friendly approach for reducing carbon emissions in cloud data centers. *Computers, Materials and Continua*. 2022 Mar 26;72(2):3175-93.
- 17) Al Kez D, Foley AM, Laverty D, Del Rio DF, Sovacool B. Exploring the sustainability challenges facing digitalization and internet data centers. *Journal of Cleaner Production*. 2022 Oct 15;371:133633.
- 18) Oluwatobi Alebiosu. Comparative analysis of public-private partnership legislation driving electricity infrastructure expansion, renewable energy investment, and economic resilience nationally. *Int J Foreign Trade Int Bus* 2025;7(2):239-249. DOI: [10.33545/26633140.2025.v7.i2c.262](https://doi.org/10.33545/26633140.2025.v7.i2c.262)
- 19) Hussain A. A systematic literature review on energy efficiency in data centers. M. Sc. Tech Thesis, Tampere University. 2024 Mar.
- 20) Agrawal A, Shrivastava K, Chakrabarty A, Singh Y, Shaw R, Padhi A. An in-depth examination of green energy options to improve power consumption efficiency and reduce carbon emissions in contemporary data

- centre infrastructures. In 2024 International Conference on Trends in Quantum Computing and Emerging Business Technologies 2024 Mar 22 (pp. 1-6). IEEE.
- 21) Chen D, Ma Y, Wang L, Yao M. Spatio-temporal management of renewable energy consumption, carbon emissions, and cost in data centers. *Sustainable Computing: Informatics and Systems*. 2024 Jan 1;41:100950.
 - 22) Daramola G. Reducing environmental compliance failures through automated regulatory reporting and real-time risk escalation in industrial operations. *Int J Res Publ Rev*. 2025;6(3):10328-10340. doi:10.55248/gengpi.06.0326.2410.
 - 23) Uddin M, Rahman AA. Energy efficiency and low carbon enabler green IT framework for data centers considering green metrics. *Renewable and Sustainable Energy Reviews*. 2012 Aug 1;16(6):4078-94.
 - 24) Adepu R. Green cloud infrastructure: Energy-aware scheduling and sustainable data center design. *International Journal of Computer Technology and Electronics Communication*. 2025 Aug 15;8(4):210-26.
 - 25) Satish S, Meduri SS. Integrating renewable energy sources into cloud computing data centers: Challenges and solutions. *Int. J. Res. Publ. Rev*. 2024 Jun;5:1598-608.
 - 26) Kwaku Gyamfi Boamah. AI-Driven Threat Intelligence Adoption in Security Operations Centers: Human Skill Erosion or Analyst Augmentation? A Comparative Case Study of Resource-Constrained SOC's in Emerging Markets. *International Journal of Science and Research Archive*, 2026, 19(03), 025-033. Article DOI: <https://doi.org/10.30574/ijstra.2026.19.3.1226>.
 - 27) Channi HK, Kumar P. Green data centers and renewable energy. In *AI Applications for Clean Energy and Sustainability 2024* (pp. 161-186). IGI Global Scientific Publishing.
 - 28) Chidolue O, Ohenhen PE, Umoh AA, Ngozichukwu B, Fafure AV, Ibekwe KI. Green data centers: sustainable practices for energy-efficient IT infrastructure. *Eng. Sci. Technol. J*. 2024 Jan;5(1):99-114.
 - 29) Murino T, Monaco R, Nielsen PS, Liu X, Esposito G, Scognamiglio C. Sustainable energy data centres: A holistic conceptual framework for design and operations. *Energies*. 2023 Aug 2;16(15):5764.
 - 30) Oluwatobi Alebiosu. Engineering stakeholder alignment frameworks for resolving land rights, environmental compliance, and project delivery conflicts. *Int J Appl Res*. 2024;10(12):401-412. DOI: [10.22271/allresearch.2024.v10.i12e.13917](https://doi.org/10.22271/allresearch.2024.v10.i12e.13917)
 - 31) Ewim DR, Ninduwezuor-Ehiobu N, Orikpete OF, Egbokhaebho BA, Fawole AA, Onunka C. Impact of data centers on climate change: a review of energy efficient strategies. *The Journal of Engineering and Exact Sciences*. 2023 Aug 17;9(6):16397-01e.
 - 32) Oró E, Depoorter V, Garcia A, Salom J. Energy efficiency and renewable energy integration in data centres. Strategies and modelling review. *Renewable and Sustainable Energy Reviews*. 2015 Feb 1;42:429-45.
 - 33) George Daramola. Assessing environmental impacts of rapid data centre expansion on energy consumption, water resources, and emissions. *Int. J. Res. Eng*. 2023;5(1):38-47. DOI: [10.33545/26648776.2023.v5.i1a.191](https://doi.org/10.33545/26648776.2023.v5.i1a.191)
 - 34) Jahid A, Haque GM, Ansari I, Azam MA. Sustainable IT infrastructure and green data analytics: measuring environmental performance in digital enterprises. *The USA Journals TAJET*. 2026 Mar 12;8(03):80-106.
 - 35) Mondal S, Faruk FB, Rajbongshi D, Efaz MM, Islam MM. GEECO: Green data centers for energy optimization and carbon footprint reduction. *Sustainability*. 2023 Oct 25;15(21):15249.
 - 36) Abdullahi Bamidele Bashiru; The Social Resource Network (SRN): A Socio-Technical Framework for Circular Waste Matchmaking. *ACS Sustainable Resour. Manage*. 26 February 2026; 3 (2): 283–285. <https://doi.org/10.1021/acssusresmgmt.5c00510>
 - 37) Chountalas PT, Chrysikopoulos SK, Agoraki KK, Chatzifoti N. Modeling critical success factors for green energy integration in data centers. *Sustainability*. 2025 Apr 15;17(8):3543.
 - 38) Cao Z, Zhou X, Hu H, Wang Z, Wen Y. Toward a systematic survey for carbon neutral data centers. *IEEE Communications Surveys & Tutorials*. 2022 Mar 22;24(2):895-936.
 - 39) Alebiosu O. AI and cybersecurity governance and legal compliance challenges affecting digital energy infrastructure, smart grids, and critical utility resilience systems. *Int J Comput Appl Technol Res*. 2026;15(8):1-14. doi:10.7753/IJCATR1508.1001.
 - 40) Huang P, Copertaro B, Zhang X, Shen J, Löfgren I, Rönnelid M, Fahlen J, Andersson D, Svanfeldt M. A review of data centers as prosumers in district energy systems: Renewable energy integration and waste heat reuse for district heating. *Applied energy*. 2020 Jan 15;258:114109.